

Attestation

M1

On the 13th of March 2026 Eurofins Product Testing A/S received a sample of a wall filler with the product name:

ProMix Mega

supplied by

Saint-Gobain Construction Product, s.r.o

The emissions were tested according to 'M1 Protocol for Chemical and Sensory Testing of Building Materials' as published by Rakennustietosäätiö (version of November 2017). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 in the latest versions (see the test report no. 392-2026-00144001_I_EN).

The tested product complies with the following requirements:

- The sum of VOC ("TVOC") after 28 days was below the limit of 0.2 mg/m²h
- Formaldehyde after 28 days was below the limit of 0.05 mg/m²h
- Ammonia after 28 days was below the limit of 0.03 mg/m²h
- Carcinogenic substances after 28 days were below the limit of 0.001 mg/m³
- Substances with an EU LCI value have a concentration lower than the LCI value
- Odour acceptance after 28 days was not worse than the limit of 0.0

This attestation does not alone entitle to use the protected trademark label M1. For the use of an M1, a license has to be applied for at the RTS, Helsinki, Finland.

21 July 2026



Tobias Sandbaek
Analytical Service Manager